9/12/2007

# **DLP-25/DLP-25AMP Series**

Data/Signal Line Surge Suppression Device For protecting Instrumentation, Telecom and Telco equipment

# 1.0 GENERAL

#### 1.1 DESCRIPTION

These specifications describe the electrical and mechanical requirements for a rapid-responding transient voltage surge suppressor. The specified surge protective device shall provide effective high-energy surge diversion for a broad range of applications. Tested & certified per UL 497. The specified surge protective device shall provide the following performance per class of DLP-25 or DLP-25AMP:

# DLP-25-xxxV5 (Heavy Duty models)

- 20,000 A (8/20us) Ipeak rating per circuit.
- All signal lines protected with respect to chassis ground.
- Protector shall be provided with DIN rail (35mm) mountable enclosure.
- Protector shall be able to be mounted to surfaces not including a DIN rail.
- Must protect five wires and use less than three inches of DIN rail space.
- Must have a series resistance no more than 6 Ohms per wire.
- Must have a maximum system current capacity of 350 mA per wire.
- TWENTY YEAR WARRANTY. Replacement units are sent from factory, located in Deer Park, New York, USA.

#### **DLP-25-xxxV2** (Standard Duty models)

- 10,000 A (8/20us) Ipeak rating per circuit.
- All signal lines protected with respect to chassis ground.
- Protector shall be provided with DIN rail (35mm) mountable enclosure.
- Protector shall be able to be mounted to surfaces not including a DIN rail.
- Must protect five wires and use less than three inches of DIN rail space.
- Must have a series resistance no more than 3 Ohms per wire.
- Must have a maximum system current capacity of 350 mA per wire.
- TWENTY YEAR WARRANTY. Replacement units are sent from factory, located in Deer Park, New York, USA.

#### **DLP-25-xxxV** (Light Duty models)

- 5,000 Watt (10/1000 microsecond) rating per circuit.
- All signal lines protected with respect to chassis ground.
- Protector shall be provided with DIN rail (35mm) mountable enclosure.
- Protector shall be able to be mounted to surfaces not including a DIN rail.
- Must protect five wires and use less than three inches of DIN rail space.
- Must have a series resistance of 0 (zero) Ohms.
- Must have a maximum system current capacity of 5A per wire when series connected and unlimited when shunt/parallel connected.
- TWENTY YEAR WARRANTY. Replacement units are sent from factory, located in Deer Park, New York, USA.

#### **DLP-25AMP-xxxW-x** (Amplifier Protector models)

- 15,000 Watt (10/1000 microsecond) rating per mode per channel.
- Protection modes shall be + to -, + to GND, to GND.
- Protector shall be provided with DIN rail (35mm) mountable enclosure.
- Protector shall be able to be mounted to surfaces not including a DIN rail.
- Protector shall be capable of protecting two channels.
- Must have a series resistance of 0 (zero) Ohms.
- Protector shall be internally fused.
- Protector shall be transparent to audio signal.
- Must be compatible with nominal speaker impedances of four or eight Ohms.
- ONE YEAR WARRANTY. Replacement units are sent from factory, located in Deer Park, New York, USA.

# 1.2 STANDARDS

The specified suppressor shall be designed, manufactured, tested and installed in compliance with:

- Institute of Electrical and Electronic Engineers IEEE-472
- Federal Communications Commission Docket 68
- Bellcore standards 974 and 1089
- National Fire Protection Association (NFPA 20, 70, 75 and 78)
- Underwriters Laboratories (497B) listed
- CAN/C22.2 No. 8-M1986; CSA Electrical Certification Notice No. 516

# 1.3 PROTECTED EQUIPMENT ELECTRICAL REQUIREMENTS

#### 1.3.1 Environmental Requirements

#### A. Operating Requirements:

- 1. Operating temperature range shall be -55°C to 65°C.
- 2. Storage temperature range shall -55°C to 75°C.
- 3. Operation shall be reliable in an environment with 0% to 95% non-condensing relative humidity.
- 4. The system shall be capable of operation up to an altitude of 13,000 feet above sea level.

# **1.3.2** Electrical Requirements

### A. Electrical Requirements:

- 1. Preferred method of ground connection, protector to protected device chassis, 6" or less lead length.
- Standard Voltage ratings available shall be 6V, 12V, 25V, 36V, 55V, 100V, 150V, and 180V and the attenuation less than 1 db @ 10 MHz for DLP-25 Heavy Duty, Standard Duty, and Light Duty models. For the DLP-25AMP amplifier protector series, protector must be able to be used with stereo amplifiers rated at up to 300 Watts rms output into 4 or 8 Ohms.
- 3. The transient suppression capability shall be bi-directional and suppress both positive and negative impulses.

2/12/2007

- 4. The suppressor shall be designed so as to minimize the internal surge path impedance. Direct point-to-point internal wiring is inherently inductive and not acceptable. Connection to the protected device shall be constructed as shown in the installation notes for best performance.
- 5. Equipment shall be as manufactured by MCG Surge Protection; Model: DLP-25/DLP-25AMP or engineering department approved equal with supporting data.

#### 2.0 ENCLOSURE AND DIMENSIONS

A. Enclosure: Aluminum

**B. Dimensions:** 2.95"L x 2.83"W x 1.86"D (74.9mm L x 71.9mm W x 47.3mm D)

# 3.0 INSTALLATION AND MAINTENANCE

- **A.** The unit shall be installed in accordance with the manufacturer's printed instruction to maintain warranty. All local and national codes must be observed.
- **B.** Units shall be installed as close as possible to the device to which it is connected
- **C.** Detailed installation/maintenance notes shall be provided to insure safety of maintenance personnel.

# **4.0 20 YEAR WARRANTY** (on DLP-25 5-wire heavy duty, standard duty, and light duty protector series)

Manufacturer to provide 20-year warranty to cover repair or replacement with a new device. Manufacturer to provide no cost replacement of DLP-25. Restrictions apply. See "Warranty & Limitations of Liability", document part No. 299-200-06.

# **4.1 1 YEAR WARRANTY** (on DLP-25AMP Amplifier protector series)

Manufacturer to provide 1-year warranty to cover repair or replacement with a new device. Manufacturer to provide no cost replacement of DLP-25AMP Amplifier protector series.

12 Burt Drive Deer Park, NY 11729 USA